

CERTIFICATE



TÜV NORD CERT GmbH
herewith declares that

Ningbo Jinshi Solar Electrical Science & Technology Co., Ltd.
No.19, Laoshan Road
Ningbo City, Zhejiang Province
315800
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:



Description of product (details see Annex 2):

PV Modules with 6" Poly-crystalline Silicon Solar Cells

Valid until: 2017-06-27

Tested according to: IEC / EN 61215:2005;
IEC 61730-1:2004 / EN 61730-1:2007;
IEC 61730-2:2004 / EN 61730-2:2007.

Remark: The fire test (MST 23 of IEC 61730-2) was performed.

Registered No.: 44 780 14 406749 - 127

Manufacturer: see Annex 1

Test Report No.: 492010541.001

File No.: GZV09024/14

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Essen, 2014-11-14

Please also pay attention to the information stated overleaf.

Manufacturer:

Manufacturer: **Ningbo Jinshi Solar Electrical Science & Technology Co., Ltd.**
No.19, Laoshan Road
Ningbo City, Zhejiang Province, 315800, P.R. China

Factory inspection report no.: 862010146.002

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:

PV Modules with 6" Poly-crystalline Silicon Solar Cells

- a) NBJ-XXXP-36 (XXX=245-320, in increments of 5)
- b) NBJ-XXXP-30 (XXX=205-260, in increments of 5)
- c) NBJ-XXXP-27 (XXX=180-240, in increments of 5)
- d) NBJ-XXXP-24 (XXX=160-210, in increments of 5)
- e) NBJ-XXXP-36*85/156 (XXX=150-170, in increments of 5)
- f) NBJ-XXXP-18 (XXX=120-160, in increments of 5)
- g) NBJ-XXXP-18*4/5 (XXX=90-125, in increments of 5)
- h) NBJ-XXXP-18*3/5 (XXX=70-95, in increments of 5)
- i) NBJ-XXXP-18*1/2 (XXX=60-80, in increments of 5)
- j) NBJ-XXXP-18*60/156 (XXX=50-60, in increments of 5)
- k) NBJ-XXXP-18*1/3 (XXX=50)
- l) NBJ-XXXP-18*1/4 (XXX=40,)
- m) NBJ-XXXP-18*36/156 (XXX=35,)
- n) NBJ-XXXP-18*28/156 (XXX=25)
- o) NBJ-XXXP-18*23/156 (XXX=20)
- p) NBJ-XXXP-18*18/156 (XXX=15)
- q) NBJ-XXXP-18*13/156 (XXX=10)
- r) NBJ-XXXP-18*12/78 (XXX=5)

Maximum system voltage: 1000V

Fuse rating: 15A

Application class: Class A

Electrical protection class: Class II

Fire safety class: C

Rated mechanical load: For a, 5400Pa

For b-d, if frame thickness=45mm, 5400Pa. Others are 2400Pa.

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.



TÜV NORD CERT GmbH
Certification Body
Consumer Products